

Lighting Product Application Guide

10 December 2018



An appropriate citation for this paper is

Essential Services Commission 2018, Lighting Product Application Guide, 10 December

Copyright notice

© Essential Services Commission 2018



This work, Lighting Product Application Guide, is licensed under a Creative Commons Attribution 4.0 licence [creativecommons.org/licenses/by/4.0]. You are free to re-use the work under that licence, on the condition that you credit the Essential Services Commission as author, indicate if changes were made and comply with the other licence terms.

The licence does not apply to any brand logo, images or photographs within the publication.

Contents

Introduction	1
About this guide	1
Who should use this guide	1
Seeking assistance	2
Legal context for this guide	2
1. Lighting product applications	3
1.1. Product criteria and documentation	3
1.2. Lighting upgrade product types	3
1.3. Project-based activity lighting applications	4
1.4. How to lodge a request to modify the register of products	4
1.5. Representing multiple products with a single test report	5
1.6. Can product approved for building based lighting also be submitted for public lighting upgrades and/or non-building based lighting upgrades?	6
1.7. Performance and safety testing of approved lighting products	6
2. Product performance and documentation requirements	8
2.1. Incandescent lighting (product category 21)	8
2.2. Product categories 27, 34 and 35: General requirements - lighting upgrade	43
2.3. Product category 27: Public lighting upgrade products	44
2.4. Product category 34: Building based lighting upgrade	52
2.5. Product category 35: Non-building based lighting upgrade	60
Glossary	69

Introduction

This guide provides product applicants with guidance on how to apply for lighting products to be listed on our Register of Products, so that they are eligible to be installed and create Victorian energy efficiency certificates (VEECs) under the Victorian Energy Upgrades (VEU) program.

About this guide

This guide provides product applicants with instructions and our documentation requirements for applying for a lighting product to be listed on our Register of Products.

The product categories covered by this guide are:

- Incandescent lighting products (product category 21)
- Public lighting upgrade products (product category 27)
- Building based lighting upgrade products (product category 34)
- Non-building based lighting activity products (product category 35)

This guide is divided into two sections:

- Section 1 provides general information and instructions on submitting lighting product applications
- Section 2 provides further detail of the documentary evidence required for the various lighting product categories

You should also read our Application Guide for Product Applicants, which provides additional information on:

- our Register of Products
- our product application and assessment process, including things to bear in mind throughout the process
- some product application functionality.

Who should use this guide

You should use this guide if you are

- applying for lighting products to be listed on our Register of Products under the Victorian Energy Upgrades program

- interested in understanding the product application requirements for lighting products under the VEU program.

You must hold a VEU account to apply for a product listing. Find out more about creating a VEU account at www.esc.vic.gov.au/become-veu-accredited

Seeking assistance

If you encounter difficulties with your application that cannot be answered using this guide contact us on (03) 9032 1310 or veu@esc.vic.gov.au

We appreciate the time and effort that businesses put into their applications and product officers will endeavour to work with you during the assessment process.

If you have submitted a product application, please use the designated 'notes' field in the online product assessment tool to communicate directly with the product officer responsible for assessing your application.

Legal context for this guide

We have prepared this guide as a general summary of relevant parts of:

- Victorian Energy Efficiency Target Act 2007 (the VEET Act)
- Victorian Energy Efficiency Target Regulations 2018 (the VEET Regulations)
- Victorian Energy Upgrades Specifications 2018 (the VEU specifications)
- Victorian Energy Efficiency Target Guidelines (the VEET guidelines)

View these documents at www.esc.vic.gov.au/veu-legislation

This guide should not be relied upon as substitute for legal advice and should be read in conjunction with the above source documents. In the event of inconsistency between this guide and the source documents, the content in the source documents apply.

1. Lighting product applications

1.1. Product criteria and documentation

Products must meet the specified requirements to be listed on the Register of Products and create VEECs. We do not accept deviations from the listed standards.

You must review and familiarise yourself with the product performance and documentation requirements for each type of product before testing products and submitting product applications.

If you are unable to provide sufficient evidence that a product is capable of meeting the minimum criteria, the product will not be approved.

For most of the product categories listed on the following pages, you must submit an independent third-party verification of the product performance against established safety and performance standards, such as a test report from an accredited laboratory.

Consult the relevant sections of the VEET Regulations and VEU specifications when preparing documentary evidence for your application.

1.2. Lighting upgrade product types

Incandescent lighting (product category 21)

Incandescent lighting products are eligible for installation in residential or non-residential premises. There are 6 different lighting products under this lighting product category

- LED GLS lamp (product category 21A)
- LED lamp for replacement of reflector (product category 21B)
- 12V non-integrated LED lamp (product category 21C)
- Mains voltage downlight LED luminaire (product category 21D)
- LED GU10 lamp with integrated driver (product category 21E)
- Mains voltage LED integrated downlight (product category 21F)

Public lighting upgrade (product category 27)

Public lighting upgrade products can be installed in public open spaces (roads and public outdoor spaces) owned by relevant bodies.

Traffic signal light replacement and sports field lighting upgrades are not eligible.

There are two main product categories under this activity:

- 'AEMO approved'
- 'ESC approved'.

You may submit products approved by AEMO to us to be included on our Register of Products in the 'AEMO approved' category. Alternatively, you can provide the documentation listed in Section 2 to show that a product meets our product requirements under Part 27 to be included in the 'ESC approved' category.

Building based lighting upgrade (product category 34)

Building based lighting upgrade products can only be installed in non-residential/business premises. Both lamps and lighting control devices are listed on our Register of Products.

Non-building based lighting upgrade (product category 35)

Non-building based lighting upgrade products are those installed in environments that are not included in public lighting upgrade (activity 27) or building based lighting upgrade (activity 34).

Eligible installation environments include outdoor spaces such as sports fields and parks.

1.3. Project-based activity lighting applications

When installing lighting products as part of project-based activities, accredited persons (APs) must select from lighting products listed on our Register of Products. If the product is not listed on our Register of Products, APs, or other applicants, may submit an application for approval under one of the lighting product categories (21, 27, 34 or 35). Please contact VEU support if the lighting product or installation environment for your project-based activity project does not fit within the requirements of these lighting product categories.

1.4. How to lodge a request to modify the register of products

As noted in Section 3.2 of the Application Guide for Product Applicants, stakeholders can request modifications to, or removal of, approved products on the Register of Products by sending an email with the required information to us at veu@esc.vic.gov.au. For example, where we have estimated the NLP of a lighting product, we will update the estimate in the Register of Products upon request upon provision of a product specification sheet.

We may decide to modify the Register of Products as a result of a request if satisfied that the modification is consistent with program requirements.

1.5. Representing multiple products with a single test report

In some circumstances, you may submit one test report to represent several similar products. Unless explicitly stated, separate tests and accreditations are required for each individual product, and each test report must identify the brand and model of the product to which it applies.

All supporting documentation must specify the product brand and model number. If different supporting documents contain different brands and/or model numbers, you must submit a manufacturer's declaration clearly reconciling the different product brands and/or model numbers used across supporting documentation.

Note: Brand/model reconciliation documents are not accepted for safety certificates or ISTMT reports; these must be issued in the exact brand and model as the product applied for.

When can I submit a representative test report for ISTMT tests?

We will accept a representative test report for an in-situ temperature measurement test (ISTMT) test if the differences between the tested product and the products represented by the report are unlikely to affect the final ISTMT result.

For example, we **will accept** one ISTMT test report to represent a series of products with the same wattage, LED chip and the electrical circuit, but with the following minor differences:

- lens material (glass vs plastic), lens design (frost vs. clear), type of cap (B22 vs E27), beam angle, light distribution (narrow, wide or oval optics), or superficial differences such as the luminaire colour or differences between installation brackets
- LED chip differences such as CCT, CRI, chromaticity coordinates, voltage bin, or flux bin.

The laboratory report must list all the differences between the lamps and provide photographic evidence of all lamps represented by the test report. The tests must be conducted on the product with the highest drive current. If the drive currents are identical across the products, test must be conducted on the product with the lowest correlated colour temperature (CCT).

We **will not accept** a representative test report in the following circumstances:

- products with different chips or different wattages
- products with additional electrical circuits (motion sensors, Wi-Fi components etc.)
- products with different thermal masses
- dimmable or non-dimmable versions of the same luminaire
- products with varying values of LCPs.

We may decide to request additional ISTMT reports if we believe that an ISTMT report is not representative of the performance of a luminaire.

When can I submit a representative test report for ingress protection tests?

You must submit a test report to confirm ingress protection (IP) rating of lamps designed for outdoor environments, including reflector lamps and non-building based lighting products.

You may submit one test report to represent several products if all the following criteria are met:

- all proposed lamps have the same external construction (housing) when compared to the tested model (the test laboratory must confirm this with relevant photographic evidence)
- statement from the laboratory that the results of the IP report applies to all models listed on the product application
- the safety certificate must contain the model and corresponding IP rating for all lamps represented by the IP test report.

When can I submit a representative test report for CISPR tests?

CISPR¹ reports must be issued in the exact brand and model as the product applied for, except as follows: We will accept one CISPR test report to represent a series of products with the same wattage where those products share the same chip and circuitry.

Products with differing wattages chips or circuitry will need to submit separate CISPR reports. Brand/model reconciliation documents are not accepted for CISPR reports.

1.6. Can product approved for building based lighting also be submitted for public lighting upgrades and/or non-building based lighting upgrades?

Products listed as building based lighting upgrade products (product category 34) may also be approved as public lighting upgrade products (product category 27) and/or non-building based lighting upgrade products (product category 35).

To apply for listing in a second product category, you can lodge a new product application, with supporting documents, using the online product application tool.

1.7. Performance and safety testing of approved lighting products

We undertake independent performance and safety testing (in consultation with Energy Safe Victoria) to ensure that products listed on our Register of Products meet the minimum criteria in the VEET Regulations and/or the minimum energy efficiency requirements in the VEU specifications.

¹ CISPR is the Comité International Spécial des Perturbations Radioélectriques. In English: International Special Committee on Radio Interference.

It is a condition of listing on the Register of Products that applicants submit products to us for testing upon request. Please note that up to six samples per product must be supplied at the applicant's expense should testing be required. We may modify the register at any time on the basis of new information received, including the results from independent testing.

Failure to submit an approved product for testing may result in the product being removed from our Register of Products.

2. Product performance and documentation requirements

2.1. Incandescent lighting (product category 21)

Product category 21A: LED GLS lamp

Attribute	Product criteria	Documentary evidence
Minimum true power factor	≥ 0.55 or ≥ 0.8 for high power factor multiplier.	<ul style="list-style-type: none">• Test report:-<ul style="list-style-type: none">– using IES LM-79-08 or other methodology from a laboratory accredited by National Association of Testing Authorities (NATA) or equivalent body– include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for²– Minimum test sample size: 10 units• Documentation showing the laboratory is accredited to perform IES LM-79-08 (if required).
Minimum CRI	Average ≥ 80 .	<ul style="list-style-type: none">• Test report:-

² This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

Attribute	Product criteria	Documentary evidence
Omnidirectional requirement ³	<ul style="list-style-type: none"> 80% of the luminous intensity measured values (candelas) shall vary by no more than 35% from the average of all measured values in the 0° to 130° zone. All measured values (candelas) in the 0° to 130° zone shall vary by no more than 60% from the average of all measured values in that zone. No less than 5% of total flux (zonal lumens) shall be emitted in the 130° to 180° zone. 	<ul style="list-style-type: none"> using IES LM-79-08 from a laboratory accredited by NATA or equivalent body must include a calculation which demonstrates compliance against each of the Product Criteria must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for - Minimum test sample size: 10 units <ul style="list-style-type: none"> Documentation showing the laboratory is accredited to perform IES LM-79-08.
Lighting source efficacy levels	<p>Four efficacy bands are specified:</p> <ol style="list-style-type: none"> Minimum light source efficacy of 84 lumens/watt Minimum light source efficacy of 100 lumens/watt Minimum light source efficacy of 120 lumens/watt Minimum light source efficacy of 140 lumens/watt 	
Colour temperature	<p>A colour temperature that is, or can be set to,</p> <ul style="list-style-type: none"> warm white (2700K to 3500K) or cool white (3500K to 4000K). 	

³ Source: U.S. Environmental Protection Agency, ENERGY STAR program. *ENERGY STAR Program Requirements for Lamps - Eligibility Criteria Version 2.0 (Rev. February 2016)*

Attribute	Product criteria	Documentary evidence
Maximum premature LED chip failure rate	10% of IES LM-80-08 or ANSI/IES LM-80-15 sample.	<ul style="list-style-type: none"> • IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15. <ul style="list-style-type: none"> – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-80-08 or ANSI/IES LM-80-15 • In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> – using Section 12.4.1 of IEC 60598.1 (or equivalent) or clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with annex A of IES LM-84-14 (the testing laboratory is not required to be accredited to LM-84-14) – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz and ambient temperature at 25 °C. – Minimum test sample size: 1 unit • The ISTMT report must be issued in the <u>exact brand and model</u> of each product applied for and include: <ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with annex A of IES LM-84-14 (the laboratory is not required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current of the LED chip(s)

Attribute	Product criteria	Documentary evidence
Lifetime	L ₇₀ (70% of original lamp light output) at 8,000 hours.	<ul style="list-style-type: none"> - clear photos: <ul style="list-style-type: none"> - identifying the product - showing the original product label listing the exact brand and model of the product applied for* - showing the exact position of the thermocouple. <p><i>** 'Forward current' is the current that flows under the application of a forward voltage. e.g., the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</i></p> <p>Notes:</p> <ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the forward current of the LED chip was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB . • Manufacturer's declaration stating: <ul style="list-style-type: none"> - the brand and model of the LED chip supplied with each brand and model of lamp applied for - the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions. • IES TM-21-11 test report:

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> - produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15 - based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report - IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. - - Minimum test sample size: 10 units • Scope of accreditation document for each testing laboratory.
EMC	Compliance with AS/NZS CISPR 15:2017.	<ul style="list-style-type: none"> • Test report:- <ul style="list-style-type: none"> - using AS/NZS CISPR 15:2017 from a laboratory accredited by NATA or equivalent body - must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for⁴ • Documentation showing the laboratory is accredited to perform AS/NZS CISPR 15:2017. • Minimum test sample size: 5 units

⁴ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

Attribute	Product criteria	Documentary evidence
Safety	Lamp complies with relevant Australian safety standards.	<p>Safety certificate issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Each safety certificate must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for safety.</i></p>
Dimmable	If the lamp is to be installed in a dimmable circuit, is approved by the manufacturer as suitable for such a circuit.	Manufacturer's declaration or product specifications (if required).

Product category 21B: LED lamp replacement of reflector

Attribute	Product criteria	Documentary evidence
Minimum true power factor	≥ 0.55 or ≥ 0.9 for high power factor.	<ul style="list-style-type: none"> • Test report:- <ul style="list-style-type: none"> – using IES LM-79-08 or other methodology from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for* – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08 (if required).
Minimum CRI	Average ≥ 80.	<ul style="list-style-type: none"> • Test report:- <ul style="list-style-type: none"> – using IES LM-79-08 or other methodology from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for* – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08.
Light output	If the lamp is to be installed in an external environment, 950 lumens.	
Minimum lighting source efficacy levels	45 lumens/watt.	
Colour temperature	A colour temperature that is, or can be set to, <ul style="list-style-type: none"> • warm white (2700K to 3500K) or • cool white (3500K to 4000K). 	

Attribute	Product criteria	Documentary evidence
Maximum premature LED chip failure rate	10% of IES LM-80-08 or ANSI/IES LM-80-15 sample.	<ul style="list-style-type: none"> • IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15. <ul style="list-style-type: none"> – Minimum test sample size: 10 units • In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> – conducted on one sample – using Section 12.4.1 of IEC 60598.1 (or equivalent) or clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with Annex A of IES LM-84-14 (the testing laboratory is not required to be accredited to LM-84-14) – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz – Minimum test sample size: 1 unit • The ISTMT report must be issued in the <u>exact brand and model</u> of each product applied for and include: <ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with annex A of IES LM-84-14 (the laboratory is not required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current** of the LED chip(s) – clear photos:
Lifetime	L ₇₀ (70% of original lamp light output) at 12,000 hours.	<ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with annex A of IES LM-84-14 (the laboratory is not required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current** of the LED chip(s) – clear photos:

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> ○ identifying the product ○ showing the original product label listing the exact brand and model of the product applied for⁵ ○ showing the exact position of the thermocouple. <p><i>** 'Forward current' is the current that flows under the application of a forward voltage, e.g. the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</i></p> <p>Notes:</p> <ul style="list-style-type: none"> ● The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. ● The ISTMT test report must explain how the forward current of the LED chip was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB⁶. ● Manufacturer's declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and model of lamp applied for

⁵ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

⁶ Applicable for all ISTMT test reports produced on or after 1st August 2018.

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions. • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15 – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units • Scope of accreditation document for each testing laboratory.
EMC	Compliance with AS/NZS CISPR 15:2017.	<ul style="list-style-type: none"> • Test report:- <ul style="list-style-type: none"> – using AS/NZS CISPR 15:2017 from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for⁷ – Minimum test sample size: 5 units • Documentation showing the laboratory is accredited to perform AS/NZS CISPR 15:2017.
Safety	Lamp complies with relevant Australian safety standards.	Safety certificate issued by a state government safety body or JAS-ANZ accredited approval provider.

⁷ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<p><i>Note: Each safety certificate must be issued in the exact brand and model as the product applied for. Band/model reconciliation documents are not accepted for safety.</i></p>
Dimmable	If the lamp is to be installed in a dimmable circuit, is approved by the manufacturer as suitable for such a circuit.	Manufacturer's declaration or product specifications (if required).
Ingress protection (IP)	If the lamp is to be installed in an external environment, a rating of IP44.	<ul style="list-style-type: none"> • Test report:- <ul style="list-style-type: none"> – using AS 60529-2004 from a laboratory accredited by NATA or equivalent body [or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999)] conducted on one sample. – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for. – Minimum test sample size: 1 unit • Documentation showing the laboratory is accredited to perform AS 60529-2004 or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999)

Product category 21C: 12V non-integrated LED lamp

Attribute	Product criteria	Documentary evidence
Minimum true power factor	<p>The combined lamp circuit power factor of the tested lamp and transformer must be ≥ 0.7 if the lamp is to be installed in residential premises or ≥ 0.9 if the lamp is to be installed in business or other non-residential premises.</p> <p>The test must be conducted with a transformer designed for anon-integrated lamp. The lamp will only be approved for installation with the same type of transformer (magnetic or electronic) that it was tested with.</p>	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 or other methodology from a laboratory accredited by National Association of Testing Authorities (NATA) or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for⁸ – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08 (if required).
Minimum CRI	Average ≥ 80 .	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for⁹
Minimum lighting source efficacy level	52 lumens/watt.	
Minimum light output	420 lumens in the forward direction.	
Colour temperature	A colour temperature that is, or can be set to, <ul style="list-style-type: none"> • warm white (2700K to 3500K) or 	

⁸ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

⁹ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

Attribute	Product criteria	Documentary evidence
	<ul style="list-style-type: none"> cool white (3500K to 4000K). 	<ul style="list-style-type: none"> Minimum test sample size: 10 units Documentation showing the laboratory is accredited to perform IES LM-79-08.
Beam angle	If the lamp is to be installed in residential premises, has a beam angle ≥ 55 degrees when determined in accordance with IEC/TR 61341 Edition 2.0.	<ul style="list-style-type: none"> Test report: <ul style="list-style-type: none"> using IEC/TR 61341 Edition 2.0 from a laboratory accredited by NATA or equivalent body (if required) must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for¹⁰ Documentation showing the laboratory is accredited to perform IEC/TR 61341 Edition 2.0, IES-LM79-08 or equivalent (if required).
Maximum premature LED chip failure rate	10% of IES LM-80-08 or ANSI/IES LM-80-15 sample.	<ul style="list-style-type: none"> IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15.
Lifetime	L ₇₀ (70% of original lamp light output) at 15,000 hours.	<ul style="list-style-type: none"> Minimum test sample size: 10 units In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> conducted on one sample using section 12.4.1 of IEC 60598.1 (or equivalent) or clause 14 of

¹⁰ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<p>ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with annex A of IES LM-84-14 (the testing laboratory <u>is not</u> required to be accredited to LM-84-14)</p> <ul style="list-style-type: none"> – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz with a representative magnetic or electronic transformer designed for halogen lamps – the ISTMT must be conducted at ambient temperature of 25°C. – Minimum test sample size: 1 unit <ul style="list-style-type: none"> • The ISTMT report must be issued in the <u>exact brand and model</u> of each product applied for and include: <ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with annex A of IES LM-84-14 (the laboratory <u>is not</u> required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current** of the LED chip(s) – clear photos: <ul style="list-style-type: none"> ○ identifying the product ○ showing the original product label listing the exact brand and model of the product applied for* ○ showing the exact position of the thermocouple. <p><i>** 'Forward current' is the current that flows under the application of a forward voltage. e.g., the DC forward current for a LED may be 30 mA when a forward</i></p>

Attribute	Product criteria	Documentary evidence
		<p><i>voltage of 2.0 V is applied.</i></p> <p>Notes:</p> <ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the forward current of the LED chip was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB¹¹. • Manufacturer’s declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and model of lamp applied for – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions. • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to

¹¹ Applicable for all ISTMT test reports produced on or after 1st August 2018.

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> perform IES LM-80-08 or ANSI/IES LM-80-15 – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units • Scope of accreditation document for each testing laboratory.
EMC (Electromagnetic compatibility)	Compliance with AS/NZS CISPR 15:2017.	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using AS/NZS CISPR 15:2017 from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for¹² – Minimum test sample size: 5 units • Documentation showing the laboratory is accredited to perform AS/NZS CISPR 15:2017
Transformer compatibility	The non-integrated LED lamp must be compatible with the type of extra-low voltage lighting converter used with the	Manufacturer's declaration or product specifications listing compatible transformers.

¹² This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
	decommissioned lamp	
Dimmable	If the lamp is to be installed in a dimmable circuit, is approved by the manufacturer as suitable for such a circuit.	Manufacturer's declaration or product specifications (if required).

Product category 21D: Mains voltage downlight LED luminaire

Attribute	Product criteria	Documentary evidence
Minimum true power factor	<p>≥ 0.55 or ≥ 0.9 for high power factor multiplier.</p> <p>The test must be conducted with the driver the lamp is supplied with. The lamp will only be approved for installation with the same driver it was tested with.</p>	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 or other methodology from a laboratory accredited by National Association of Testing Authorities (NATA) or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and, where relevant, the exact brand and model of the remote control gear supplied with the product – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08 (if required).
Minimum CRI	Average ≥ 80 .	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and, where relevant, the exact brand and model of the remote control gear supplied with the product – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08.
Lighting source efficacy	48 lumens/watt.	
Light output	400 lumens in the forward direction.	
Colour temperature	<p>A colour temperature that is, or can be set to either,</p> <ul style="list-style-type: none"> • warm white (2700K to 3500K) • cool white (3500K to 4000K). 	

Attribute	Product criteria	Documentary evidence
Beam angle	If the lamp is to be installed in residential premises, has a beam angle ≥ 40 degrees when determined in accordance with IEC/TR 61341 Edition 2.0.	<ul style="list-style-type: none"> • Test report <ul style="list-style-type: none"> – using IEC/TR 61341 Edition 2.0 from a laboratory accredited by NATA or equivalent body (if required) – test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for* – Minimum test sample size: 1 unit • Documentation showing the laboratory is accredited to perform IEC/TR 61341 Edition 2.0, IES-LM79-08 or equivalent (if required).
Maximum premature LED chip failure rate	10% of IES LM-80-08 or ANSI/IES LM-80-15 sample.	<ul style="list-style-type: none"> • IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15. • Minimum test sample size: 10 units • In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> – conducted on one sample – using Section 12.4.1 of IEC 60598.1 (or equivalent) or Clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with Annex A of IES LM-84-14 (the testing laboratory is not required to be accredited to LM-84-14) – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz with the

Attribute	Product criteria	Documentary evidence
Lifetime	L ₇₀ (70% of original lamp light output) at 15,000 hours.	<p>control gear supplied with the lamp.</p> <ul style="list-style-type: none"> – The ISTMT must be conducted at ambient temperature of 25°C. – Minimum test sample size: 1 unit • The ISTMT report must be issued in the <u>exact brand and model</u> of each product applied for and include: <ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with Annex A of IES LM-84-14 (the laboratory <u>is not</u> required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current** of the LED chip(s) – clear photos; <ul style="list-style-type: none"> ○ identifying the product ○ showing the original product label listing the exact brand and model of the product applied for and, where relevant, the original product label listing the exact brand and model of the remote control gear supplied with the product.¹³ ○ showing the exact position of the thermocouple. <p><i>** 'Forward current' is the current that flows under the application of a forward voltage. e.g., the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</i></p>

¹³ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<p>Notes:</p> <ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the forward current of the LED chip was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB¹⁴. • Manufacturer’s declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and model of lamp applied for – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions. • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15 – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test

¹⁴ Applicable for all ISTMT test reports produced on or after 1st August 2018

Attribute	Product criteria	Documentary evidence
		<p>report</p> <ul style="list-style-type: none"> – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units <ul style="list-style-type: none"> • Scope of accreditation document for each testing laboratory.
EMC	Compliance with AS/NZS CISPR 15:2017.	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using AS/NZS CISPR 15:2017 from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and, where relevant, the exact brand and model of the remote control gear supplied with the product¹⁵ – Minimum test sample size: 5 units • Documentation showing the laboratory is accredited to perform AS/NZS CISPR 15:2017.
Safety	Driver/luminaire complies with relevant Australian safety standards.	<p>Safety certificate issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Each safety certificate must be issued in the exact brand and model as</i></p>

¹⁵ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<i>the product applied for. Brand/model reconciliation documents are not accepted for safety.</i>
Dimmable	If the lamp is to be installed in a dimmable circuit, is approved by the manufacturer as suitable for such a circuit.	Manufacturer's declaration or product specifications (if required).

Product category 21E: LED lamp with integrated driver and GU10 base

Attribute	Product criteria	Documentary evidence
GU10 base	Must be an LED lamp with integrated driver and GU10 base	Product specification sheet.
Minimum true power factor	≥ 0.55 or ≥ 0.9 for high power factor multiplier	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 or other methodology from a laboratory accredited by National Association of Testing Authorities (NATA) or equivalent body. – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for¹⁶ – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08 (if required).
Minimum CRI	Average ≥ 80 .	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for¹⁷
Lighting source efficacy	48 lumens/watt.	
Light output	400 lumens in the forward direction.	
Colour temperature	A colour temperature that is, or can be set to either,	

¹⁶ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
	<ul style="list-style-type: none"> warm white (2700K to 3500K) cool white (3500K to 4000K). 	<ul style="list-style-type: none"> Minimum test sample size: 10 units Documentation showing the laboratory is accredited to perform IES LM-79-08.
Beam angle	If the lamp is to be installed in residential premises, has a beam angle ≥ 55 degrees when determined in accordance with IEC/TR 61341 edition 2.0.	<ul style="list-style-type: none"> Test report: <ul style="list-style-type: none"> using IEC/TR 61341 edition 2.0 from a laboratory accredited by NATA or equivalent body (if required) the test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for Minimum test sample size: 1 unit Documentation showing the laboratory is accredited to perform IEC/TR 61341 Edition 2.0, IES-LM79-08 or equivalent (if required).
Maximum premature LED chip failure rate	10% of IES LM-80-08 or ANSI/IES LM-80-15 sample.	<ul style="list-style-type: none"> IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15. <ul style="list-style-type: none"> Minimum test sample size: 10 units In-situ temperature measurement test (ISTMT):
Lifetime	L ₇₀ (70% of original lamp light output) at 15,000 hours.	

¹⁷ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> - conducted on one sample - using section 12.4.1 of IEC 60598.1 (or equivalent) or clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with annex A of IES LM-84-14 (the testing laboratory is not required to be accredited to LM-84-14) - must be conducted at 230V(+10%/-6%), 50 Hz with the control gear supplied with the lamp - must be conducted at ambient temperature of 25°C. - Minimum test sample size: 1 unit • The ISTMT report must be issued in the exact brand and model of each product applied for and include: <ul style="list-style-type: none"> - statement that the ISTMT was conducted in accordance with annex A of IES LM-84-14 (the laboratory is not required to be accredited to IES LM-84-14) - the brand and model of the LED chip(s) - the forward current** of the LED chip(s) - clear photos: <ul style="list-style-type: none"> ○ identifying the product ○ showing the original product label listing the exact brand and model of the product applied for* ○ showing the exact position of the thermocouple. <p>** 'Forward current' is the current that flows under the application of a forward</p>

Attribute	Product criteria	Documentary evidence
		<p><i>voltage. e.g., the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</i></p> <p><u>Notes:</u></p> <ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the forward current of the LED chip was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB¹⁸. • Manufacturer’s declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and model of lamp applied for – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions. • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15

¹⁸ Applicable for all ISTMT test reports produced on or after 1st August 2018

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units • Scope of accreditation document for each testing laboratory.
EMC	Compliance with AS/NZS CISPR 15:2017.	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using AS/NZS CISPR 15:2017 from a laboratory accredited by NATA or equivalent body – the test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for¹⁹ – Minimum test sample size: 5 units • Documentation showing the laboratory is accredited to perform AS/NZS CISPR 15:2017
Safety	Lamp complies with relevant Australian safety standards.	<p>Safety certificate issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Each safety certificate must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted</i></p>

¹⁹ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<i>for safety.</i>
Dimmable	If the lamp is to be installed in a dimmable circuit, is approved by the manufacturer as suitable for such a circuit.	Manufacturer's declaration or product specifications (if required).

Product category 21F: Mains voltage LED integrated downlight

Attribute	Product criteria	Documentary evidence
Downlight fitting	The product must be a mains voltage downlight LED integrated luminaire.	Product specification sheet.
Minimum true power factor	≥ 0.55 or ≥ 0.9 for high power factor.	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 or other methodology from a laboratory accredited by National Association of Testing Authorities (NATA) or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and, where relevant, the exact brand and model of the remote control gear supplied with the product²⁰ – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08 (if required).
Minimum CRI	Average ≥ 80 .	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 from a laboratory accredited by NATA or equivalent body
Lighting source efficacy	48 lumens/watt.	
Light output	400 lumens in the forward direction.	

²⁰ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
Colour temperature	A colour temperature that is, or can be set to, <ul style="list-style-type: none"> • warm white (2700K to 3500K) or • cool white (3500K to 4000K). 	<ul style="list-style-type: none"> – the test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and, where relevant, the exact brand and model of the remote control gear supplied with the product – Minimum test sample size: 10 units • Documentation showing the laboratory is accredited to perform IES LM-79-08.
Beam angle	If the product is to be installed in residential premises, the beam angle must be ≥ 40 degrees when determined in accordance with IEC/TR 61341 edition 2.0.	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IEC/TR 61341 edition 2.0 from a laboratory accredited by NATA or equivalent body (if required) – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for – Minimum test sample size: 1 unit • Documentation showing the laboratory is accredited to perform IEC/TR 61341 Edition 2.0, IES-LM79-08 or equivalent (if required).
Maximum premature LED chip failure rate	10% of IES LM-80-08 or ANSI/IES LM-80-15 sample.	<ul style="list-style-type: none"> • IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15.
Lifetime	L ₇₀ (70% of original lamp light output) at 15,000 hours.	<ul style="list-style-type: none"> – Minimum test sample size: 10 units • In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> – conducted on one sample

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> – using section 12.4.1 of IEC 60598.1 (or equivalent) or clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with annex A of IES LM-84-14 (the testing laboratory is not required to be accredited to LM-84-14). – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz with the control gear supplied with the lamp. the ISTMT must be conducted at ambient temperature of 25°C. – Minimum test sample size: 1 unit • The ISTMT report must be issued in the exact brand and model of each product applied for and include: <ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with Annex A of IES LM-84-14 (the laboratory is not required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current** of the LED chip(s) – clear photos: <ul style="list-style-type: none"> ○ identifying the product ○ showing the original product label listing the exact brand and model of the product applied for and, where relevant, the original product label listing the exact brand and model of the remote control gear supplied with the product* ○ showing the exact position of the thermocouple.

Attribute	Product criteria	Documentary evidence
		<p>** 'Forward current' is the current that flows under the application of a forward voltage. e.g., the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</p> <p>Notes:</p> <ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the LED chip forward current was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB²¹. • Manufacturer's declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and model of lamp applied for – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions.

²¹ Applicable for all ISTMT test reports produced on or after 1st August 2018

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15 – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units • Scope of accreditation document for each testing laboratory.
EMC	Compliance with AS/NZS CISPR 15:2017.	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using AS/NZS CISPR 15:2017 from a laboratory accredited by NATA or equivalent body – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and, where relevant, the exact brand and model of the remote control gear supplied with the product²² – Minimum test sample size: 5 units • Documentation showing the laboratory is accredited to perform AS/NZS CISPR 15:2017.

²² This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

Attribute	Product criteria	Documentary evidence
Safety	Product complies with relevant Australian safety standards.	<p>Safety certificate issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Each safety certificate must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for safety.</i></p>
Dimmable	If the product is to be installed in a dimmable circuit, is approved by the manufacturer as suitable for such a circuit.	Manufacturer's declaration or product specifications (if required).

2.2. Product categories 27, 34 and 35: General requirements - lighting upgrade

Approval documentation summary

Table 1: Summary of documentary evidence required for each light source type under product categories 27, 34 and 35 of the VEET Regulations

Product type	Documentation requirements									
	Specifications	MEPS	NLP	LCP	Lifetime	Safety	EMC	Power factor (≥ 0.90)	Compatibility range	Voltage
T5, T8 or T12 fluorescent lamp only CFL (GLS)	Lamp /LCDs	Lamp ¹			Lamp					
T5, T8 or T12 lamp with ballast (luminaire)	Lamp / LCDs	Lamp			Lamp	Luminaire				
LED lamp with integrated driver LED lamp with non-integrated driver or ELC LED highbay LED tube (lamp only) LED tube (luminaire) LED downlight with integral driver (240V) LED ELV downlight with 240V remote driver	Lamp / control gear / luminaire / LCDs		Lamp & control gear	Lamp & control gear	Lamp	Lamp / control gear / luminaire	Lamp / control gear / luminaire			

LED other (240V) CFL lamp Induction lamp										
LED ELV downlight (lamp only)	Lamp		Lamp	Lamp & transformer	Lamp		Lamp	Lamp & transformer	Lamp ²	
VRU unit					Unit	Unit			Unit	Unit
LCD	Unit					Unit	Unit		Unit	

¹ MEPS registration is not required for T5, T8 or T12 fluorescent lamps with an NLP of 14W or 15W; however in such cases evidence of the NLP must be provided.

² The installer must ensure compatibility of the lamp with the existing transformer.

2.3. Product category 27: Public lighting upgrade products

AEMO approved products to be installed under public lighting upgrade (activity 27) are not required by the VEET Regulations to be listed on our Register of Products at the time of installation. However, from an IT systems perspective, all products need to be recorded in our Register of Products in order to create VEECs in our registry system. Accordingly, for AEMO approved products, you will need to apply to us (with minimal supporting documentation) to have a product listed on our register prior to creating VEECs for these activities.

There are two main approval pathways for public lighting upgrade products and to obtain listing on our Register of Products:

- AEMO-approved: When proposing a AEMO approved luminaire, please submit the brand, model, nominal lamp power, evidence of lamp lifetime (refer to the following table for evidentiary requirements) and a screenshot of the product listing in AEMO’s NEM Load Table²³.
- Commission approved: When proposing non-AEMO-approved products, you need to submit the evidence detailed in table below to demonstrate that the product meets the program’s legislative requirements.

Attribute	Product criteria	Documentary evidence
Safety & EMC	<ul style="list-style-type: none"> • Luminaire complies with AS/NZS 60598.1 and AS/NZS 60598.2.3 • Control gear complies with AS/NZS 61347.2.13 	<p>Safety certificates with Regulatory Compliance Mark (RCM) issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Safety certificates must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for safety.</i></p>
Ingress protection (IP)	<ul style="list-style-type: none"> • Optical chamber is rated IP65 • Control gear chamber is rated IP65 (unless the control gear is rated IP65, then the control gear chamber can be rated IP24). 	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using AS 60529-2004 from a laboratory accredited by NATA or equivalent body [or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999)] – Minimum test sample size: 1 unit – the test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for²⁴

²³ At the time of publication, the AEMO NEM Load Table was available at https://www.aemo.com.au/-/media/Files/Electricity/NEM/Retail_and_Metering/Metering-Procedures/NEM-Load-Tables-For-Unmetered-Connection-Points.pdf

²⁴ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> • Documentation showing the laboratory is accredited to perform AS 60529-2004[or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999) • You may submit a representative test report (see Section 1.4) for a number of products if all the following criteria are met: <ul style="list-style-type: none"> – All proposed lamps must have the same external construction (housing) when compared to the tested model. The test laboratory must confirm this with relevant photographic evidence – Statement from the laboratory must confirm that the results of the IP report apply to all models listed in the report – The safety certificate must list the model and corresponding IP rating for all proposed lamps.
Lamp circuit power (LCP)	N/A	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using IES LM-79-08 from a laboratory accredited by NATA or equivalent body – the test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and the exact brand and model of the remote control gear supplied with the product²⁵
Power factor	Combined power factor of the lamp and control gear must be ≥ 0.90 .	
Lighting efficacy	100 lumens/watt.	
Correlated colour temperature (CCT)	2700K to 5700K for streetlights	

²⁵ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
Colour rendering index (CRI)	≥ 70.	<ul style="list-style-type: none"> – Minimum test sample size: 1 unit • Corresponding IES photometric files • Documentation showing the laboratory is accredited to perform IES LM-79-08.
Lifetime	N/A	<ul style="list-style-type: none"> • IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15. <ul style="list-style-type: none"> – Minimum test sample size: 10 units • In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> – conducted on one sample – using Section 12.4.1 of IEC 60598.1 (or equivalent) or Clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with Annex A of IES LM-84-14 (the testing laboratory is not required to be accredited to LM-84-14) – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz with the control gear supplied with the lamp. – the ISTMT must be conducted at ambient temperature of 25°C. – Minimum test sample size: 1 unit • The ISTMT report must be issued in the <u>exact brand and model</u> of each product applied for and include:

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> - statement that the ISTMT was conducted in accordance with Annex A of IES LM-84-14 (the laboratory is not required to be accredited to IES LM-84-14) - the brand and model of the LED chip(s) - the forward current** of the LED chip(s) - clear photos: <ul style="list-style-type: none"> o identifying the product o showing the original product label listing the exact brand and model of the product applied for and the original product label listing the exact brand and model of the remote control gear supplied with the product* o showing the exact position of the thermocouple. <p>** <i>'Forward current' is the current that flows under the application of a forward voltage. e.g., the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</i></p> <p>Notes:</p> <ul style="list-style-type: none"> • ISTMT reports must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for ISTMT reports. • We will accept a representative ISTMT test report (see_Section 1.4) in the instances where differences between the models are not likely to influence the ISTMT result. Some examples are lamp colour temperature (CCT), CRI, lens material, holder/end cap or beam angle. However, the laboratory must

Attribute	Product criteria	Documentary evidence
		<p>declare all the differences between the lamps and provide photographic evidence of all lamps represented by the test report. The tests must be conducted on the product with the highest drive current. If the drive currents are identical, test must be conducted on the product with the lowest CCT. We require individual ISTMT tests for all other proposed products.</p> <ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the LED chip forward current was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB²⁶. • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • Manufacturer’s declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and

²⁶ Applicable for all ISTMT test reports produced on or after 1st August 2018

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> model of lamp applied for – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions. • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15 – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units • Scope of accreditation document for each testing laboratory.
Specifications	N/A	Product specification sheet showing the specifications of the product, including (where relevant), the number of lamps contained in the luminaire.

The table below outlines the documentary evidence required for standalone LCD devices eligible for installation in public spaces.

Attribute	Product criteria	Documentary evidence	Min. test sample size
Safety & EMC	Electrical safety certificate with RCM compliance	<p>Safety certificates with Regulatory Compliance Mark (RCM) issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Safety certificates must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for safety.</i></p>	

Attribute	Product criteria	Documentary evidence	Min. test sample size
Ingress protection (IP)	Rated IP65	<ul style="list-style-type: none"> • Test report: <ul style="list-style-type: none"> – using AS 60529-2004 from a laboratory accredited by NATA or equivalent body [or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999)] conducted on one sample – must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for²⁷ – Minimum test sample size: 1 unit • Documentation showing the laboratory is accredited to perform AS 60529-2004[or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999) • You may submit a representative test report (see Section 1.4) for a number of products if all the following criteria are met: <ul style="list-style-type: none"> – All proposed LCDs must have the same external construction (housing) when compared to the tested model. The test laboratory must confirm this with relevant photographic evidence – Statement from the laboratory must confirm that the results of the IP report apply to all models listed in the report 	

²⁷ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence	Min. test sample size
		<ul style="list-style-type: none"> The safety certificate must list the model and corresponding IP rating for all proposed LCDs. 	
Specifications	N/A	Product specification sheet showing the specifications of the product, showing functionality of the product	

2.4. Product category 34: Building based lighting upgrade products

Attribute	Product type	Documentary evidence
Specifications	All	<ul style="list-style-type: none"> Product specification sheet showing the specifications of the product, including (where relevant), type and specifications of LCDs built into to lamps All lamp specifications must show an NLP value for each proposed luminaire
MEPS	<ul style="list-style-type: none"> T5, T8, or T12 fluorescent lamp CFL (GLS) 	Screen shot of MEPS registration details from www.energyrating.gov.au .
NLP	<ul style="list-style-type: none"> T5, T8, or T12 fluorescent lamp CFL (GLS) 	Screen shot of MEPS registration details from www.energyrating.gov.au , manufacturer's product specification sheet or declaration.

Attribute	Product type	Documentary evidence
	<ul style="list-style-type: none"> • Metal halide • Mercury vapour • High pressure sodium 	<ul style="list-style-type: none"> • Manufacturer's product specification sheet or declaration • Specification sheet or declaration must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for²⁸.
LCP	<ul style="list-style-type: none"> • LED highbay • LED tube (lamp only) • LED tube (luminaire) • LED downlight with integral driver (240V) • LED ELV downlight with 240V remote driver • LED other (240V) • CFL downlight • induction • fluorescent lamp 	<ul style="list-style-type: none"> • Test report from laboratory accredited by NATA or equivalent body showing the combined lamp circuit power (LCP) of the lamp and control gear (in watts) • The LCP must be tested at 230V (+10%/-6%), 50 Hz • The LCP may be reported as a part of the ISTMT test report • Test must be conducted with the lamp and control gear the product will be supplied and installed with • If the safety certificate provided is for the control gear only, the LCP report must either:- <ul style="list-style-type: none"> – state the exact brand and model number of the control gear tested with the lamp. – screenshot of product on IPART public list of accepted emerging lighting technology showing the exact brand and model of the product applied for and the LCP. We may request further supporting documentation if required.
	LED ELV downlight (lamp only)	<ul style="list-style-type: none"> • Test report from laboratory accredited by NATA or equivalent body showing the lamp circuit power (LCP) of the lamp and a transformer (in watts) • The LCP must be tested at 230V (+10%/-6%), 50 Hz

²⁸ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

Attribute	Product type	Documentary evidence
		<ul style="list-style-type: none"> • The LCP may be reported as a part of the ISTMT test report • The lamp must be tested with a representative magnetic or electronic transformer designed for halogen lamps • The lamp will only be approved for installation with the same type of transformer (magnetic or electronic) that it was tested with. • The LCP test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for²⁹.
Lifetime	Non-LEDs	<ul style="list-style-type: none"> • Manufacturer's product specification sheet or declaration • The specification sheet must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and, where relevant, the exact brand and model of the remote control gear supplied with the product³⁰.
	LEDs	<ul style="list-style-type: none"> • IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15. <ul style="list-style-type: none"> – Minimum test sample size: 10 units • The LM-80 test must be conducted under minimum of two temperatures. One of the test conditions must be either 55°C or 85°C.

²⁹ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

³⁰ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date

Attribute	Product type	Documentary evidence
		<ul style="list-style-type: none"> • In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> – using section 12.4.1 of IEC 60598.1 (or equivalent) or clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with annex A of IES LM-84-14 (the testing laboratory <u>is not</u> required to be accredited to LM-84-14) – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz with the control gear supplied with the lamp – LED ELV downlights (lamp only) must be tested at 230V (+10%/-6%), 50 Hz with a representative magnetic or electronic transformer designed for halogen lamps – the ISTMT must be conducted at ambient temperature of 25°C. – Minimum test sample size: 1 unit • The ISTMT report must be issued in the <u>exact brand and model</u> of each product applied for and include: <ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with annex A of IES LM-84-14 (the laboratory <u>is not</u> required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current** of the LED chip(s) – clear photos: <ul style="list-style-type: none"> ○ identifying the product ○ showing the original product label listing the exact brand and model of the product applied for and, where relevant, the original product label listing the exact brand and model of the remote control gear supplied with the product*

Attribute	Product type	Documentary evidence
		<ul style="list-style-type: none"> ○ showing the exact position of the thermocouple. <p><i>** 'Forward current' is the current that flows under the application of a forward voltage. e.g., the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</i></p> <p>Notes:</p> <ul style="list-style-type: none"> • ISTMT reports must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for ISTMT reports. • We will accept a representative ISTMT test report (see Section 1.4) in the instances where differences between the models are not likely to influence the ISTMT result. Some examples are lamp colour temperature (CCT), CRI, lens material, holder/end cap or beam angle. However, the laboratory must declare all the differences between the lamps and provide photographic evidence of all lamps represented by the test report. The tests must be conducted on the product with the highest drive current. If the drive currents are identical, test must be conducted on the product with the lowest CCT. We require individual ISTMT tests for all other proposed products. • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the LED chip forward current was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire

Attribute	Product type	Documentary evidence
		<p>such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB³¹.</p> <ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • Manufacturer's declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and model of lamp applied for – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions. • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15 – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units

³¹ Applicable for all ISTMT test reports produced on or after 1st August 2018

Attribute	Product type	Documentary evidence
		<ul style="list-style-type: none"> • Scope of accreditation document for each testing laboratory.
Safety	All relevant	<p>Safety or Regulatory Compliance Mark (RCM) issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: The original safety certificate and any addendums/modifications must be submitted. The safety certificate must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for safety.</i></p> <p>or</p> <p>Screenshot of product on the IPART public list of accepted emerging lighting technology showing the exact brand and model of the product applied for (not accepted for VRUs). We may request further supporting documentation as required.</p>
EMC	All relevant	<ul style="list-style-type: none"> • Completed Australian Communications and Media Authority (ACMA) Supplier's Declaration of Conformity (listing product brand and models applied for and the supplier's code number); or • Screen shot of product registration details on the national equipment registration system database https://equipment.erac.gov.au/Registration/; or • Regulatory Compliance Mark (RCM) certificate of approval; or • Screenshot of product on the IPART public list of accepted emerging lighting technology showing the exact brand and model of the product applied for (not accepted for LED ELV downlights – lamp only). We may request further supporting documentation as required.
Power factor (≥ 0.90)	LED ELV downlight (lamp only)	<ul style="list-style-type: none"> • Test report from laboratory accredited by NATA or equivalent body showing the combined power factor of the lamp and a transformer

Attribute	Product type	Documentary evidence
		<ul style="list-style-type: none"> • The power factor must be tested at 230V (+10%/-6%), 50 Hz • When applicable the lamp must be tested with a representative magnetic or electronic transformer designed for halogen lamps • The lamp will only be approved for installation with the same type of transformer (magnetic or electronic) that it was tested with • The test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for³².
Compatibility range	LED ELV downlight (lamp only)	Manufacturer's product specification sheet or declaration listing all electronic and/or magnetic transformers (including dimmable transformers) that the lamp is compatible with.
Voltage	VRU	<ul style="list-style-type: none"> • Test report from a laboratory accredited by NATA or equivalent body showing the output voltage of the VRU • The test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for³³
LCD type	LCD	<ul style="list-style-type: none"> • Product specification sheet showing type and functionality of the LCD

³² This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

³³ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

2.5. Product category 35: Non-building based lighting upgrade products

The table in this section outlines the documentary evidence required for LED lamps and lighting control devices eligible for installation in non-building based environments. For instructions on how to apply for an existing approved Part 34 product to be approved as a Part 35 product, please see Section 1.6.

Attribute	Product criteria	Documentary evidence
Safety & EMC	<ul style="list-style-type: none"> Luminaire complies with AS/NZS 60598.1 and AS/NZS 60598.2.5 Control gear complies with AS/NZS 61347.2.13. 	<p>Safety certificates with Regulatory Compliance Mark (RCM) issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Safety certificates must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for safety.</i></p>
Ingress protection (IP)	<ul style="list-style-type: none"> Optical chamber is rated IP65 Control gear chamber is rated IP65 (unless the control gear is rated IP65, then the control gear chamber can be rated IP24). 	<ul style="list-style-type: none"> Test report using AS 60529-2004 from a laboratory accredited by NATA or equivalent body [or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999)] <ul style="list-style-type: none"> Minimum test sample size: 1 unit The test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for³⁴ Documentation showing the laboratory is accredited to perform AS 60529-2004[or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989)]

³⁴ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<p>with Amendment 1(1999)</p> <ul style="list-style-type: none"> • You may submit a representative test report (see Section 1.4) for a number of products if all the following criteria are met: <ul style="list-style-type: none"> – all proposed lamps must have the same external construction (housing) when compared to the tested model. The test laboratory must confirm this with relevant photographic evidence – statement from the laboratory must confirm that the results of the IP report apply to all models listed in the report – the safety certificate must list the model and corresponding IP rating for all proposed lamps.
Suitability for outdoor environments	<ul style="list-style-type: none"> • Luminaire complies with specific clauses of AS/NZS 60598.2.5 relevant to luminaires for use outdoors above ground level. 	<ul style="list-style-type: none"> • Safety test report showing compliance to all aspects of Clause 5.6.5 of AS/NZS 60598.2.5 <ul style="list-style-type: none"> – Minimum test sample size: 1 unit • The test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and the exact brand and model of the remote control gear supplied with the product³⁵ • Documentation showing the laboratory is accredited to perform AS/NZS 60598.2.5

³⁵ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> • You may submit a representative test report for a number of products from the same family, if the following criteria are met: <ul style="list-style-type: none"> – A safety test report with test standard AS/NZS 60598.2.5 can be submitted for a product with the highest wattage (worst case) – Statement from the laboratory confirming that safety report applies to all other models – Safety certificate must list all proposed lamps on the same certificate.
Lamp circuit power (LCP)	N/A	<ul style="list-style-type: none"> • Test report using IES LM-79-08 from a laboratory accredited by NATA or equivalent body <ul style="list-style-type: none"> – Minimum test sample size: 1 unit
Power factor	Combined power factor of the lamp and control gear must be ≥ 0.90	<ul style="list-style-type: none"> • The test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for and the exact brand and model of the remote control gear supplied with the product³⁶
Lighting efficacy	100 lumens/watt	
Colour rendering index (CRI)	≥ 70	<ul style="list-style-type: none"> • Corresponding IES photometric files • Documentation showing the laboratory is accredited to perform IES LM-79-08.

³⁶ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence
Lifetime	N/A	<ul style="list-style-type: none"> • IES LM-80-08 or ANSI/IES LM-80-15 test report from a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15. <ul style="list-style-type: none"> – Minimum test sample size: 10 units • In-situ temperature measurement test (ISTMT): <ul style="list-style-type: none"> – conducted on one sample – using Section 12.4.1 of IEC 60598.1 (or equivalent) or Clause 14 of ANSI/UL 1598 from a laboratory accredited by NATA or equivalent body to perform that test. The ISTMT must be conducted in accordance with Annex A of IES LM-84-14 (the testing laboratory is not required to be accredited to LM-84-14) – the ISTMT must be conducted at 230V (+10%/-6%), 50 Hz with the control gear supplied with the lamp. <ul style="list-style-type: none"> – The ISTMT must be conducted at ambient temperature of 25°C. – Minimum test sample size: 1 unit • The ISTMT report must be issued in the exact brand and model of each product applied for and include: <ul style="list-style-type: none"> – statement that the ISTMT was conducted in accordance with Annex A of IES LM-84-14 (the laboratory is not required to be accredited to IES LM-84-14) – the brand and model of the LED chip(s) – the forward current** of the LED chip(s) – clear photos:

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> ○ identifying the product ○ showing the original product label listing the exact brand and model of the product applied for and the original product label listing the exact brand and model of the remote control gear supplied with the product* ○ showing the exact position of the thermocouple. <p><i>** 'Forward current' is the current that flows under the application of a forward voltage. e.g., the DC forward current for a LED may be 30 mA when a forward voltage of 2.0 V is applied.</i></p> <p>Notes:</p> <ul style="list-style-type: none"> ● ISTMT reports must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for ISTMT reports. ● We will accept a representative ISTMT test report (see Section 1.4) in the instances where differences between the models are not likely to influence the ISTMT result. Some examples are lamp colour temperature (CCT), CRI, lens material, holder/end cap or beam angle. However, the laboratory must declare all the differences between the lamps and provide photographic evidence of all lamps represented by the test report. The tests must be conducted on the product with the highest drive current. If the drive currents are identical, test must be conducted on the product with the lowest CCT. We require individual ISTMT tests for all other proposed products.

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • The ISTMT test report must explain how the LED chip forward current was determined. The laboratory may explain forward current using the construction of the LEDs within the luminaire such as the parallel LED arrays (strings), number of LED chips in an array, average drive current of a LED array, and/or total drive current of the COB³⁷. • The ISTMT temperature and LED chip forward current of the tested product must be equal to or lower than the highest temperature and/or forward current tested in the IES LM-80-08 or ANSI/IES LM-80-15 report or the lifetime of the product cannot be established and it will not be approved. • Manufacturer's declaration stating: <ul style="list-style-type: none"> – the brand and model of the LED chip supplied with each brand and model of lamp applied for – the forward current of the LED chip(s) used in each lamp when operating under normal Australian conditions.

³⁷ Applicable for all ISTMT test reports produced on or after 1st August 2018

Attribute	Product criteria	Documentary evidence
		<ul style="list-style-type: none"> • IES TM-21-11 test report: <ul style="list-style-type: none"> – produced by a laboratory accredited by NATA or equivalent body to perform IES LM-80-08 or ANSI/IES LM-80-15 – based on the corresponding IES LM-80-08 or ANSI/IES LM-80-15 test report – IES LM-80-08 or ANSI/IES LM-80-15 reports that contain a TM-21-11 calculation are acceptable. – Minimum test sample size: 10 units • Scope of accreditation document for each testing laboratory.
Specifications	N/A	Product specification sheet showing the specifications of the product, including , NLP and types of LCDs (if any)

Attribute	Product criteria	Documentary evidence	Min. test sample size
Safety & EMC	Electrical safety certificate with RCM compliance	<p>Safety certificates with Regulatory Compliance Mark (RCM) issued by a state government safety body or JAS-ANZ accredited approval provider.</p> <p><i>Note: Safety certificates must be issued in the exact brand and model as the product applied for. Brand/model reconciliation documents are not accepted for safety.</i></p>	N/A
Ingress protection (IP)	Rated IP65	<ul style="list-style-type: none"> • Test report using AS 60529-2004 from a laboratory accredited by 	

Attribute	Product criteria	Documentary evidence	Min. test sample size
		<p>NATA or equivalent body [or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999)]</p> <ul style="list-style-type: none"> – Minimum test sample size: 1 unit • The test report must include a photograph that clearly shows the product with the original product label listing the exact brand and model of the product applied for³⁸ • Documentation showing the laboratory is accredited to perform AS 60529-2004[or equivalent standard IEC 60529 Ed.2.1 2001 or IEC 60529 (1989) with Amendment 1(1999)] • You may submit a representative test report (see Section 1.4) for a number of products if all the following criteria are met: <ul style="list-style-type: none"> – all proposed LCDs must have the same external construction (housing) when compared to the tested model. The test laboratory must confirm this with relevant photographic evidence – statement from the laboratory must confirm that the results of the IP report apply to all models listed in the report – the safety certificate must list the model and corresponding IP rating for all proposed LCDs. 	

³⁸ This requirement is mandatory for test reports issued on or after 1 May 2017 and optional for test reports issued before this date.

Attribute	Product criteria	Documentary evidence	Min. test sample size
Specifications	N/A	Product specification sheet showing the specifications of the product, including functionality of the LCD	

Glossary

General definitions

Term	Definition
Accredited body	In relation to a product, this means a body accredited under the Joint Accreditation System of Australia and New Zealand to give product certification or component certification of a product.
AEMO	Australian Energy Market Operator
AP	An accredited person is a business that has been accredited by the commission to operate within the VEU Program. An AP is entitled to create VEECs through the undertaking of energy efficient activities which are prescribed under the VEET Regulations.
Approved laboratory	Means a laboratory that is accredited by the National Association of Testing Authorities under a mutual recognition agreement.
Business/non-residential premises	Under the VEU program, business/non-residential premises are defined as: (i) the premises that is not registered as a residential premises (see definition below), and (ii) the premises not registered as a 'scheduled activity premises' unless it has been 'opted in' to the VEU Program pursuant to Regulation 10AA of the VEET Regulations.
DNSP	Distribution network service provider
EMC	Electromagnetic compatibility
Equivalent body	A testing body recognised by NATA under a mutual recognition agreement.
ESV	Energy Safe Victoria
IPART	Independent Pricing and Regulatory Tribunal of New South Wales, the administrator of the New South Wales' Energy Savings Scheme.
NATA	National Association of Testing Authorities
RCM	Regulatory Compliance Mark
Residential premises	A building classified under part A3 of the Building Code of Australia as a class 1, 2, 3, or 4 building.
VEEC	Victorian energy efficiency certificate. Each VEEC represents one tonne of carbon dioxide equivalent (CO ₂ -e) abated by the prescribed activity.

Lighting-specific terms

Term	Definition
CCT	Correlated colour temperature
CRI	Colour rendering Index
ELV	Extra low voltage
Forward current	The current that flows under the application of a forward voltage.
IP	Ingress protection
ISTMT	In-situ temperature measurement test
LCD	Lighting control devices are used to control the lighting output of a light fitting, for example occupancy sensors, daylight-linked controls, programmable dimmers, manual dimmers and voltage reduction units.
LCP	Lamp circuit power, in relation to the lamp, means the power drawn by the lamp and the power drawn by any associated ballast or transformer, which is divided equally between the lamp and any other lamps associated with the ballast or transformer.
LED	Light emitting diode
Light output	The quantity and distribution of the visible light produced by a light source.
Lighting Source Efficacy	The initial luminous flux of a lamp or the total radiant flux in the visible spectrum weighted by the spectral response of the eye, divided by the electric power that will be consumed by the lamp but excluding ballast and control gear power losses.
NLP	Nominal lamp power is the manufacturer's rated value for power drawn by a single lamp.
VRU	A voltage reduction unit is a product used to reduce voltage to a light fitting.
Extra low voltage lighting converter	As per AS/NZS 4879.1; a magnetic transformer or a electronic step down converter used with ELV lamps, which, <ul style="list-style-type: none"> receives an input from mains supply has single ELV (extra low voltage) output (either ac or dc) is sold with, or intended to be used with, ELV lamps(s) that constitute the primary load
CFL	Compact florescent lamp
Control gear	A device for the control of one or more light sources but does not include a lighting control device. Example: Ballasts, transformers, and step down converters such as drivers
Downlight	A luminaire mounted flush with a surface, with a light source aperture whose largest dimension is less than 20 centimeters

Term	Definition
LED integrated luminaire	A product that contains a LED device and the equipment required to distribute, filter or transform the light being transmitted and includes: <ul style="list-style-type: none"> • all parts necessary for supporting, fixing and protecting the product and for connecting the product to the electricity supply • any lighting control device for the product
LED lamp with integrated driver	A self-ballasted LED module, incorporating control gear and any additional elements necessary for stable operation, that is designed for direct connection to an electricity supply
Luminaire	A non-integrated luminaire or a LED integrated luminaire;
NBB lighting	Non building based lighting is lighting undertaken under the part 35 of the VEET Regulations
Non-integrated LED lamp	A LED module where the control gear is separate from the LED module for operation under constant voltage, constant current or constant power
Non-integrated luminaire	A device that distributes, filters or transforms the light transmitted from one or more lamps that are separate from the device and includes all parts necessary for fixing and protecting the lamps and for connecting the lamps to the electricity supply;

Document version control

The RM reference for this document is: C/18/24088

Version	Amendments made	Date published
1.0	First release	10 December 2018